

TEXAS COMMISSION ON FIRE PROTECTION
DRIVER/OPERATOR - PUMPER
Performance Standards Evaluation

Skill #14
OPERATIONS – Supplying Water to a Standpipe System

PERFORMANCE STANDARD

Section 700

NFPA 1002-5.2.4

Driver/Operator

OBJECTIVE

Supply water to fire sprinkler and standpipe systems, given specific system information and a fire department pumper, so that water is supplied to the system at the correct volume and pressure. (5.2.4)

INSTRUCTIONS - procedures for achieving the objective

The Driver/Operator-Pumper candidate shall position a fire department pumper, connect to a hydrant and provide water supply to a fire department connection (FDC) to support a standpipe system.

EXAMINER'S NOTE

The Driver/Operator – Pumper candidate will not be allowed to review the performance steps at the time of testing.

PREPARATION & EQUIPMENT

Fire department pumper
Specific standpipe system information
Hydrant
FDC

TEXAS COMMISSION ON FIRE PROTECTION
DRIVER/OPERATOR - PUMPER
 Performance Standards Evaluation

Candidate: _____ Notes: _____

Training Provider: _____

Test Site: _____

Driver/Operator – Pumper	<u>TEST</u>		<u>RETEST</u>	
	S	U	S	U
Skill #14	S	U	S	U
Supply water to fire sprinkler and standpipe systems, given specific system information and a fire department pumper, so that water is supplied to the system at the correct volume and pressure. (5.2.4)				
The candidate:	S	U	S	U
a) Positioned the pumping apparatus to supply the FDC from a fire hydrant				
b) Transferred power from vehicle engine to pump				
c) Operated the volume/pressure transfer valve (multistage pumps only)				
d) Removed cap(s) and inspected FDC for: debris, damaged threads, and gasket				
e) Connected supply hose line(s) to the FDC				
f) Established water supply from fire hydrant				
g) Supplied water to standpipe system				
h) Pumped appropriate pressure at FDC				
i) Operated pumper pressure control systems				
j) Operated auxiliary cooling systems				
k) Maintained safe residual pressure				
l) Performed skill in a safe and proficient manner				

S = Satisfactorily completed/performed

U = Unsatisfactorily performed/failed to meet objective or grading step

Examiner/Candidate Comments:

Reprinted with permission from NFPA 1002, Fire Apparatus Driver/Operator Professional Qualifications, Copyright ©2013, National Fire Protection Association, Quincy, MA 02169. This reprinted material is not the complete and official position of the National Fire Protection Association on the referenced subject which is represented only by the standard in its entirety.

TEXAS COMMISSION ON FIRE PROTECTION
DRIVER/OPERATOR - PUMPER
Performance Standards Evaluation

All steps of the skill objective are mandatory and must be scored as “Satisfactory” to pass the skill.

_____	_____	Driver Skill Sheet
Certifying Examiner	Date	Pass <input type="checkbox"/> Fail <input type="checkbox"/>
_____	_____	Driver Skill Sheet Re-Test
Re-Test Certifying Examiner	Date	Pass <input type="checkbox"/> Fail <input type="checkbox"/>

Reprinted with permission from NFPA 1002, Fire Apparatus Driver/Operator Professional Qualifications, Copyright ©2013, National Fire Protection Association, Quincy, MA 02169. This reprinted material is not the complete and official position of the National Fire Protection Association on the referenced subject which is represented only by the standard in its entirety.